



**Material Prüfinstitut
Hellberg GmbH**

Bessemerstraße 10 A
21339 Lüneburg

Tel.: +49 4131 75 77 01
Fax: +49 4131 75 77 02
Email: info@mpi-gmbh.de
Internet: www.mpi-gmbh.de

Test certificate No.: 12 4433 - S / 08

Date: 03.01.2008

Page 1 of 2

Customer: Benecke-Kaliko AG
Beneckallee 40
D-30419 Hannover

Order No.: n.n.

Date of order: 18.12.2007

Type of test: Testing of floorcoverings in accordance with DIN 51130, Slip Resistance "Ramp Test".

Testing material:

Trade name: 8669 Flightfloor Classic, charge no.: 3157829, color:
(declaration by customer) Swimmingpool, grain 205, transverse to production direction

Format of test item: 100 cm x 50 cm (Length x Width)
(according to DIN 51130 / BGR181)

Surface structure: structured, lined
Format of single tile: endless coil

The pages 1 and 2 show the complete test result. They may just be published together

Test

Date of test: 03.01.2008

Standards / regulations: **DIN 51130 (Ausgabe 2004-06):** Bestimmung der rutschhemmenden Eigenschaft – Arbeitsräume und Arbeitsbereiche mit erhöhter Rutschgefahr.
BGR 181: Merkblatt für Fußböden in Arbeitsräumen und Arbeitsbereichen mit Rutschgefahr.

Joint width of item for testing: 0 cm

Test result:

Average angle: 25,3°
Average displacement: not tested

Classification: R 12

Classification of displacement: not applicable

Validity of this certificate

Owing to possible changes in regulations (test / standards) and technical innovations, the validity of this certificate is limited for the duration of 5 years until the 03.01.2013.

The test results are only valid for products which are identical with the tested item. The correlation between the item tested and the production lot is not controlled by MPI Hellberg GmbH!

General informations

Certificates may only be copied and published with permission of the MPI Hellberg GmbH without any changes.

The publishing and copying of shortened versions is only permitted after consulting with MPI Hellberg GmbH.

